

CERTIFICATE OF COMPLIANCE

Certificate Number 20171213-EX27158
Report Reference EX27158-20160727
Issue Date 2017-DECEMBER-13

Issued to: Jindal Saw Limited
A59/60, MIDC-Malegaon
Sinnar, Nashik MH 422113 INDIA

**This is to certify that
representative samples of**

METALLIC SPRINKLER PIPE
All pipes with threaded ends shall conform to ANSI B1.20.1.

Schedule 40 (Seamless Pipes) steel sprinkler pipe 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6 and 8 in. sizes, as per ASTM A53/53M-12 and ASTM A795/A795M-13, Type S, Grade A and B.

Schedule 80 (Seamless Pipes) steel sprinkler pipe 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 3, 4, 5, 6 and 8 in. Sizes, as per ASTM A53/53M-12 and ASTM A795/A795M-13, Type S, Grade A and B..

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 852 Metallic Sprinkler Pipe for Fire Protection Service.

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

